



Title:	<b>017 - Pressure Test Form</b>		
Document #:	Q-Infra-TF-BDINS-905	Folder:	Inspections
Revision #:	2	Issue Date:	May 2019

**HYDROSTATIC PRESSURE & LEAKAGE TEST RESULTS**

Project Number: \_\_\_\_\_  
 Project \_\_\_\_\_  
 Description: \_\_\_\_\_  
 Contractor: \_\_\_\_\_  
 Date: \_\_\_\_\_

3 Hr Allowable Leakage: (Pipe Diameter in mm x Length in Km x 0.123)

SECTION	PIPE DIA (MM)	PIPE LENGTH (KM)	ALLOWABLE (L)

**TEST LOG**

START TIME: \_\_\_\_\_ START PRESSURE (Psi): \_\_\_\_\_  
 END TIME: \_\_\_\_\_ END PRESSURE (Psi): \_\_\_\_\_  
 TOTAL TIME: \_\_\_\_\_ TOTAL PRESSURE LOSS: \_\_\_\_\_

ALLOWABLE TOTAL LEAKAGE IN 3 Hrs: \_\_\_\_\_  
 AMOUNT OF MAKE UP WATER USED (L/3 Hrs) : \_\_\_\_\_

<p><b>PASS:</b> _____  <b>FAIL:</b> _____</p>
---

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

In Attendance: \_\_\_\_\_  
 \_\_\_\_\_

Inspector: \_\_\_\_\_

